

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/17/2010  
FORM APPROVED  
OMB NO. 0938-0391

RECEIVED

MAR 29 2010

Division of Health Care  
Enforcement Branch

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>185437</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED  <b>03/03/2010</b>
--	---	--	---

NAME OF PROVIDER OR SUPPLIER  <b>THE VILLAGE OF LEBANON II</b>	STREET ADDRESS <b>105 VILLAGE WAY LEBANON, KY 40033</b>
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
F 000	<b>INITIAL COMMENTS</b>	F 000		
F 248 SS-E	<p>A standard health survey was conducted on March 1-3, 2010. Deficient practice was identified at an 'E' level.</p> <p><b>483.15(f)(1) ACTIVITIES MEET INTERESTS/NEEDS OF EACH RES</b></p> <p>The facility must provide for an ongoing program of activities designed to meet, in accordance with the comprehensive assessment, the interests and the physical, mental, and psychosocial well-being of each resident.</p> <p>This REQUIREMENT is not met as evidenced by: Based on observation, interview, and record review, the facility failed to ensure an ongoing program of activities was provided for six of six residents who attended the group meeting. Residents in the group meeting stated there were not enough activities on the weekends and the residents were bored.</p> <p>The findings include: A group interview on March 2, 2010, at 3:00 p.m., with residents #12, #13, #14, #15, #16, and #17 revealed there were not enough activities on the weekends and the residents stated they were bored.</p> <p>A review of the March 2010 activity calendar revealed the activity scheduled for Saturday, March 6, 13, and 27, 2010, at 10:00 a.m., was watching television in the resident's room, and the activity scheduled at 6:00 p.m. was Dominoes. The activity calendar for March 20, 2010, listed an activity at 2:00 p.m., as a Remembrance Service</p>	F 248	<p><b>F248</b></p> <p>It is the policy and practice of this facility that residents will have an ongoing program of activities that are designed to meet, in accordance with the comprehensive assessment, the interests and the physical, mental, and social well-being of each resident.</p> <p>The facility has changed the Activity Aide's workweek schedule. As a result of this change there is an Activity Aide scheduled to work every Saturday (Please see Attachment A). The activity calendar will reflect this change by offering a program of activities on Saturday's that meet the interests and the physical, mental and social well-being of each resident. (Please see attachment B.) Volunteer Ackle George will continue to lead Sunday morning activities (leading the rosary, providing communion, and Mass On Air). Sunday afternoon activities will continue to be led by volunteers from the Central Baptist Association who have an alternating schedule of offering Protestant church services. (Please see Attachment B)</p>	

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE <i>Dawn Blandford MHA, LHA</i>	TITLE <i>Administrator</i>	(X6) DATE <i>3/26/10</i>
---	-------------------------------	-----------------------------

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICESPRINTED: 03/17/2010  
FORM APPROVED  
OMB NO. 0938-0391


STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  185437	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED  03/03/2010
NAME OF PROVIDER OR SUPPLIER  THE VILLAGE OF LEBANON II			STREET ADDRESS, CITY, STATE, ZIP CODE 105 VILLAGE WAY LEBANON, KY 40033	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
F 248	<p>Continued From page 1</p> <p>and at 6:00 p.m., Dominoes. The activity calendar further revealed an activity of Dominoes at 6:00 p.m. on every day of the month except March 7, 2010, March 17, 2010, and March 28, 2010.</p> <p>An interview with the Activities Director (AD) on March 3, 2010, at 10:00 a.m., revealed the AD worked 30 hours weekly on Monday through Friday. On Mondays and Wednesdays the AD worked from 9:00 a.m. until 4:00 p.m. On Tuesdays, Thursdays, and Fridays the AD worked from 9:00 a.m. until 3:30 p.m. The AD stated an activity aide worked on Tuesdays and Fridays from 1:45 p.m. until 4:00 p.m., and on Thursdays from 10:00 a.m. until 4:00 p.m. The AD stated there was no activity staff working the weekends at present. The AD stated volunteers come in and provide church services on Sundays but there were no volunteers on Saturdays at present. The AD further stated Dominoes were scheduled at 6:00 p.m. on most days and was self-initiated by a group of residents who could assist themselves. The AD stated that the activity of "watch television in your room" was listed on Saturdays, and that residents who did not have a television and were able, could come out to the day rooms/dining rooms to watch television.</p> <p>Interviews with two CNAs on March 3, 2010, at 10:50 a.m. and 11:00 a.m., revealed that the CNAs worked every other weekend, and that volunteers came in on Sundays to assist residents with activities. The CNAs did not know of any volunteers that came on Saturdays. The CNAs did not assist with any activities, and stated they were not responsible to provide residents with activities.</p>	F 248	<p>F248 cont.</p> <p>The evening activities (6:00 p.m.) have also been adjusted to offer a variety of activities. (Please see attachment B.) The Activity Director will post on the Nursing Assistants assignment sheet what evening activity is being offered and where supplies are located. The Nursing Assistants will be responsible for reminding residents of the scheduled evening activity, setting up the activity, and ensuring residents that want to participate can.</p> <p>All of these changes to the Activity Department schedules and programming will be reviewed with residents in the March Resident Council meeting to ensure that all affected residents are aware of the changes. The changes will also be listed in the April facility newsletter that is given to all residents and families. The April activity calendar will be provided to all residents and families to ensure that they are aware of changes.</p> <p>To prevent re-occurrence the facility budget has been adjusted for the activity department to include activity staff on Saturdays. Activity staff schedules have also been adjusted to include weekend staffing coverage. Weekend staffing will be required for the activity aide position and job responsibilities.</p>	

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/17/2010  
FORM APPROVED  
OMB NO. 0938-0391


STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  185437	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED  03/03/2010
NAME OF PROVIDER OR SUPPLIER  THE VILLAGE OF LEBANON II			STREET ADDRESS, CITY, STATE, ZIP CODE 105 VILLAGE WAY LEBANON, KY 40033	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
F 248	Continued From page 2 An interview with the Administrator on March 3, 2010, at 1:25 p.m., revealed no volunteers or activity personnel worked on Saturdays. The Administrator stated on Sundays volunteers provided activities of church services and visitations. The Administrator further stated no activity staff worked in the evenings (past 4:00 p.m. on Monday through Friday).	F 248	F248 cont.  The facility will monitor performance of these changes utilizing the Quality Assurance Committee. The Activity Director will submit to the Quality Assurance Committee activity department staffing schedules and the activity calendar.	4/1/10



SUNDAY	MONDAY	TUESDAY	WEDNESDAY	THURSDAY	FRIDAY	SATURDAY
<p><b>PARTICIPATION KEY</b></p> <p>YELLOW-ACTIVE PINK- PASSIVE BLUE- DECLINE</p>				<p><b>1 April Fools Day!</b></p> <p>10AM ENTERPRISE 11AM YAHTZEE 2PM BINGO 3PM BOWLING /EXERCISE 3:30PM ROSARY 6PM SPADES</p>	<p><b>2 BEAUTY SHOP</b></p> <p>10AM ALZHIEMERS MEETING 2PM BINGO/SNACKS 3PM PASS THE TRASH/ EXERCISE 3:30PM ROSARY 6PM MEMORY CARDS</p>	<p><b>3</b></p> <p>2PM BINGO 3:30PM BALL TOSS 4PM BOOK TRIVIA /EXERCISE 6PM SCRABBLE</p>
<p><b>4</b></p> <p><b>Happy Easter!</b></p> <p>10AM ROSARY 10:30AM MASS ON AIR 2:30PM <u>CHURCH IS CANCELLED FOR TODAY</u> 6PM DOMINOES</p>	<p><b>5</b></p> <p>11AM STORY HOUR IN MDR 2PM BINGO/ SNACKS 3PM EGG DESIGNS /EXERCISE 3:30PM ROSARY 6PM GIN</p>	<p><b>6</b></p> <p>10AM MASS IN MDR 2PM BINGO 3PM TELL THE TRUTH /EXERCISE 3:30PM NAIL FUN 6PM YATHZEE</p>	<p><b>7</b></p> <p>10AM BONANZA 2PM BINGO 3PM BEAN BAG TOSS/EXERCISE 3:30PM ROSARY 6PM ROOK</p>	<p><b>8</b></p> <p>10AM CHURCH CHOIR IN MDR 11AM ENTERPRISE 2PM COLORS OF FAITH CRAFT 3PM BALLOON TOSS /EXERCISE 3:30PM ROSARY 6PM SPADES</p>	<p><b>9 BEAUTY SHOP</b></p> <p>10AM ONE ON ONE 2PM BINGO/SNACKS 3PM PASS THE TRASH/ EXERCISE 3:30PM ROSARY 6PM MEMORY CARDS</p>	<p><b>10</b></p> <p>2PM BINGO 3:30PM BOOK TRIVIA 4PM PASS THE BOMB /EXERCISE 6PM SCRABBLE</p>
<p><b>11</b></p> <p><b>Happy B-day Roxie Orland</b></p> <p>10AM ROSARY 10:30AM MASS ON AIR 2:30PM BRADFORDSVILLE BAPTIST CHURCH 6PM DOMINOES</p>	<p><b>12</b></p> <p>11AM STORY HOUR IN MDR 2PM BINGO/ SNACKS 3PM EXERCISE/ PASS THE BOMB 3:30PM ROSARY 6PM GIN</p>	<p><b>13</b></p> <p>10AM COMMUNION IN MDR 2PM KIMS COOKING CLUB IN MDR 2:45PM BINGO IN MDR 3:45PM NAIL FUN 6PM YATHZEE</p>	<p><b>14</b></p> <p>10AM ALZHIEMERS MEETING 2PM BINGO 3PM BASKETBALL / EXERCISE 3:30PM ROSARY 6PM ROOK</p>	<p><b>15</b></p> <p>10AM PAINTING 11AM ENTERPRISE 2PM BINGO/MENS MEETING BIRTHDAY PARTY FOR EVERYONE THIS MONTH 3PM TRIVIA-FLASH CARDS 3:30PM ROSARY 6PM SPADES</p>	<p><b>16 BEAUTY SHOP</b></p> <p>10AM TEA SOCIAL 11AM OUTSIDE VISIT 2PM BINGO/SNACKS 3PM PASS THE TRASH/ EXERCISE 3:30PM ROSARY 6PM MEMORY CARDS</p>	<p><b>17</b></p> <p>2PM BINGO 3:30PM BALL TOSS 4PM BOOK TRIVIA /EXERCISE 6PM SCRABBLE</p>
<p><b>18</b></p> <p>10AM ROSARY 10:30AM MASS ON AIR 2:30PM CHURCH WITH PEGGY B. 6PM DOMINOES</p>	<p><b>19</b></p> <p><b>Happy B-day Anna Gowdy!</b></p> <p>11AM STORY HOUR IN MDR 2PM BINGO/SNACKS RESIDENT COUNCIL 3PM CORNHOLE /EXERCISE 3:30PM ROSARY 6PM GIN</p>	<p><b>20</b></p> <p>10AM COMMUNION IN MDR 2PM BINGO 3PM TELL THE TRUTH / EXERCISE 3:30PM BIBLE STUDY 3:30PM NAIL FUN 6PM YAHTZEE</p>	<p><b>21</b></p> <p><b>Happy B-day Wanda Sanders!</b></p> <p>10AM JOHN WAYNE MOVIE 2PM BINGO 3PM BEAN BAG TOSS / EXERCISE 3:30PM ROSARY 6PM ROOK</p>	<p><b>22</b></p> <p><b>BEAUTY SHOP</b></p> <p>10AM PUZZLE 11AM ENTERPRISE 2PM THERAPY CRAFTS 3PM BALLOON TOSS /EXERCISE 3:30PM ROSARY 6PM SPADES</p>	<p><b>23 BEAUTY SHOP</b></p> <p>12PM LUNCHEON 2PM BINGO/SNACKS 3PM PASS THE TRASH/ EXERCISE 3:30PM ROSARY 6PM MEMORY CARDS</p>	<p><b>24</b></p> <p>2PM BINGO 3:30PM PASS THE BOMB 4PM BOOK TRIVIA/EXERCISE 6PM SCRABBLE</p>
<p><b>25</b></p> <p>10AM ROSARY 10:30AM MASS ON AIR 2:30PM GRAVEL SWITCH BAPTIST CHURCH 6PM DOMINOES</p>	<p><b>26</b></p> <p>11AM STORY HOUR IN MDR 2PM BINGO/BANANA SPLITS 3PM PASS THE BOMB/EXERCISE 3:30PM ROSARY 6PM GIN</p>	<p><b>27</b></p> <p>10AM COMMUNION IN MDR 2PM BINGO 3PM TRIVIA-FLASH CARD/ EXERCISE 3:30PM NAIL FUN 6PM YAHTZEE</p>	<p><b>28</b></p> <p><b>Happy B-day Joseph Young!</b></p> <p>10AM ALZHIEMERS MEETING 1:30PM LIBRARIAN CRAFTS 2:30PM BINGO / EXERCISE 3:30PM ROSARY 6PM ROOK</p>	<p><b>29</b></p> <p><b>BEAUTY SHOP</b></p> <p>10AM WORD PUZZLES 11AM ENTERPRISE 2PM PLANTING TIME 3PM BOWLING/EXERCISE 3:30PM ROSARY 6PM SPADES</p>	<p><b>30</b></p> <p><b>BEAUTY SHOP</b></p> <p>10:30AM OUT TO EAT 2PM BINGO/SNACKS 3PM PASS THE TRASH/ EXERCISE 3:30PM ROSARY 6PM MEMORY CARDS</p>	

NAME-Last	First	Attending Physician	Record No.	Room/Bed
-----------	-------	---------------------	------------	----------

Attachment B



DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>185437</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>02 - MAIN BUILDING 01</b> B. WING _____	(X3) DATE SURVEY COMPLETED <b>03/02/2010</b>
--	---	---	---

NAME OF PROVIDER OR SUPPLIER <b>THE VILLAGE OF LEBANON II</b>	STREET ADDRESS, CITY, STATE, ZIP CODE <b>105 VILLAGE WAY LEBANON, KY 40033</b>
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	INITIAL COMMENTS  A life safety code survey was initiated and concluded on March 2, 2010, for compliance with Title 42, Code of Federal Regulations, 483.70 and found the facility not in compliance with NFPA 101 Life Safety Code, 2000 Edition.	K 000		
K 018 SS=D	Deficiencies were cited with the highest deficiency identified at a 'D'. <b>NFPA 101 LIFE SAFETY CODE STANDARD</b>  Doors protecting corridor openings are constructed to resist the passage of smoke. Doors are provided with positive latching hardware. Dutch doors meeting 18.3.6.3.6 are permitted. Roller latches are prohibited. 18.3.6.3  This STANDARD is not met as evidenced by: Based on observation and interview, the facility failed to ensure one double set of corridor doors was constructed to resist the passage of smoke.  The findings include:  The Life Safety Code tour on March 2, 2010, at 11:00 a.m., with the Director of Maintenance, revealed a corridor double door to a storage room next to the dining room area had an approximate 3/8-inch gap between the doors. These doors could not resist the passage of smoke in a fire situation. The Director was not aware corridor doors should be constructed to resist the passage of smoke.	K 018	<b>K018</b> The corridor double doors to the Central storage room next to the dining area will have meeting-style weather-stripping that will resist the passage of smoke and complies with NFPA 101 section 18.3.6.3. added to the door. (Please see attachment C and D.) This was ordered from Lebanon Lumber on 3/23/10 and will be installed immediately upon receipt. (Please see attachment C).	3/23/10
K 038	<b>NFPA 101 LIFE SAFETY CODE STANDARD</b>	K 038		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE <i>Devin Blandford MHA, LHA</i>	TITLE <i>Administrator</i>	(X8) DATE <i>3/26/10</i>
--	-------------------------------	-----------------------------

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/17/2010  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  185437	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED  03/02/2010
NAME OF PROVIDER OR SUPPLIER  THE VILLAGE OF LEBANON II			STREET ADDRESS, CITY, STATE, ZIP CODE 105 VILLAGE WAY LEBANON, KY 40033	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 038 SS=D	Continued From page 1  Exit access is arranged so that exits are readily accessible at all times in accordance with section 7.1. 18.2.1  This STANDARD is not met as evidenced by: Based on observation and interview, the facility failed to ensure that an exit had a durable surface to the public way.  The findings include:  During the Life Safety Code tour on March 2, 2010, at 11:15 a.m., with the Director of Maintenance, an exit located next to resident room 119 was noted to exit to a grassy area. Exits must have a durable surface to the public way to support foot traffic, wheelchairs, beds, equipment, etc., in case of an emergency situation. The Director stated plans were in place to connect an additional building at this exit but was unsure if the project was going to go forward.	K 038	<b>K038</b> The exit located next to resident room 119 will have a durable surface to the public way added that will support foot traffic, wheelchairs, beds, equipment, etc. This surface will comply with NFPA 101, section 7.1 and 18.2.1. The maintenance director is currently receiving bids for this project (please see attachment E and F) and construction on this project will begin as soon as the weather permits and the company we choose to utilize can start work.	3/22/10
K 050 SS=F	NFPA 101 LIFE SAFETY CODE STANDARD  Fire drills are held at unexpected times under varying conditions, at least quarterly on each shift. The staff is familiar with procedures and is aware that drills are part of established routine. Responsibility for planning and conducting drills is assigned only to competent persons who are qualified to exercise leadership. Where drills are conducted between 9 PM and 6 AM a coded announcement may be used instead of audible alarms. 18.7.1.2	K 050		

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/17/2010  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  185437	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED  03/02/2010
NAME OF PROVIDER OR SUPPLIER  THE VILLAGE OF LEBANON II			STREET ADDRESS, CITY, STATE, ZIP CODE 103 VILLAGE WAY LEBANON, KY 40033	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 050	Continued From page 2  This STANDARD Is not met as evidenced by: Based on interview and record review, the facility failed to conduct fire drills to ensure that staff was prepared for response to incidence of fire under different staffing levels and conditions to include resident levels of alertness. This failure affected all residents and staff in the facility.  The findings include:  During the Life Safety Code survey on March 2, 2010, at 11:55 a.m., with the Director of Maintenance, a record review revealed the facility had not been performing fire drills at unexpected times and varying conditions on the second shift as follows: six fire drills on the second shift from December 2008 to February 2010 were conducted between 3:00 p.m. and 3:35 p.m. An interview with the Director of Maintenance on March 2, 2010, at 12:00 p.m., revealed the Director was not aware of this requirement.	K 050	<b>K050</b> It is the policy and procedure of this facility to conduct fire drills at unexpected times under varying conditions, at least quarterly on each shift.  The fire drill schedule has been revised to ensure that fire drills will be performed at unexpected times and varying conditions during second shift (please see attachment G).  The facility will monitor performance of these changes utilizing the Quality Assurance Committee. The maintenance director will submit to the Quality Assurance Committee a report of all fire drills performed during that quarter. The report will include the dates and the times the fire drills were performed.	4/1/10





# BRADY PAVING, LLC

1497 McElroy Pike  
LEBANON, KY 40033

Pat Brady  
(270) 692-9346

Danny Brady  
(270) 692-2738  
Call (270) 699-1200

## PURCHASE ORDER

003604

THIS NUMBER MUST APPEAR ON ALL CORRESPONDENCE, INVOICES, SHIPPING PAPERS AND PACKAGES

VILLAGE OF LEBANON  
 105 VILLAGE WAY  
 LEBANON, KY 40033  
 C/ MR KE VEATCH 692-9000 402 3541

DATE ORDERED: -3-26-10    DATE WANTED:    SHIP VIA:    TERMS:    F.O.B.:

PLEASE ENTER OUR ORDER FOR THE FOLLOWING — TO BE SHIPPED AS DIRECTED:

QTY ORDERED	QTY RECEIVED	DESCRIPTION	UNIT PRICE	AMOUNT
		6' WIDE ASPHALT PATHWAY FROM STAIRS TO PARKING LOT. ABOUT 250' LONG ROCK IS TO BE Laid 8' WIDE X 4" THICK ASPHALT TO BE 6' WIDE X 2 1/2" THICK		
		GRADE & PREPARE	800. <sup>00</sup>	
		PLACING & ROLLING STONE	1500. <sup>00</sup>	
		NEW COVERT WORK	300. <sup>00</sup>	
		ASPHALT	2400. <sup>00</sup>	
		TOTAL	5000. <sup>00</sup>	
		NOTE NO GRAV SOWING OR ANY EXTRA DIRT HAS BEEN FIGURED. ALSO, MAKE SURE THE SLOPE IS NOT TO STEEP FOR YOUR NEEDS.		

GOODS ARE SUBJECT TO OUR INSPECTION AND APPROVAL. SHIPMENT WILL BE DELAYED FOR ANY REASON. ADVISE US IMMEDIATELY STATING ALL THE NECESSARY FACTS TO AVOID ERRORS. NOTE SPECIFICATIONS CAREFULLY AND BE ABLE TO COMPLETE ORDERS AS WRITTEN NOTIFY US PROMPTLY.

BY Danny  
PURCHASING AGENT

# BRADY PAVING, LLC

1497 McElroy Pike  
LEBANON, KY 40033

Pat Brady  
(270) 692-9348

Danny Brady  
(270) 692-2738  
Cell (270) 699-1200

## PURCHASE ORDER

003600

THIS NUMBER MUST APPEAR ON ALL CORRESPONDENCE, INVOICES, SHIPPING PAPERS AND PACKAGES

<b>T O</b>	Village of Lebanon 105 Village Way Lebanon, Ky 40033 ATTN: MIKE 402-3541	<b>S H I P T O</b>
------------	---	--------------------

DATE ORDERED - 3-22-10	DATE WANTED	SHIP VIA	TERMS	P.O.B.
---------------------------	-------------	----------	-------	--------

PLEASE ENTER OUR ORDER FOR THE FOLLOWING - TO BE SHIPPED AS DIRECTED:

QTY ORDERED	QTY RECEIVED	DESCRIPTION	UNIT PRICE	AMOUNT
		250' x 10'		
		278 SQUARE YARDS		
		EXTENDING GUTTER DRAIN	300. <sup>00</sup>	
		GRADE & PREPARE DIRT FOR ROAD	800. <sup>00</sup>	
		INSTALLING ROCK 6" THICK	2070. <sup>00</sup>	
		LAYING ASPHALT 2 1/2" THICK	3365. <sup>00</sup>	
		TOTAL		6535. <sup>00</sup>

CONDITIONS:  
 GOODS ARE SUBJECT TO CLOSE INSPECTION AND APPROVAL.  
 IF SHIPMENT WILL BE DELAYED FOR ANY REASON, ADVISE US IMMEDIATELY STATING ALL THE NECESSARY FACTS.  
 TO AVOID ERRORS, NOTE SPECIFICATIONS CAREFULLY AND IF UNABLE TO COMPLETE ORDERS AS WRITTEN, NOTIFY US PROMPTLY.

BY Danny - 270-699-1200  
 PURCHASING AGENT

Attachment F

Revised 2010 Fire Drill Schedule

April -December 2010

Month	Shift	Time of Drill
April	2nd	7:00 PM
May	1st	1:30 PM
June	3rd	11:00 PM
July	1st	10:30 AM
August	2nd	3:00 PM
September	3rd	6:00 AM
October	2nd	9:00 PM
November	1st	2:30 PM
December	3rd	10:00 PM

Attachment G