

ID PREFIX		MET	NOT MET	N/A	REMARKS
K72	Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. No furnishings, decorations, or other objects shall obstruct exits, access thereto, egress there from, or visibility thereof shall be in accordance with 7.1.10, 18.2.1, 19.2.1				
ILLUMINATION					
K45	Illumination of means of egress, including exit discharge, is arranged so that failure of any single lighting fixture will not leave the area in darkness. Lighting system shall be either continuously in operation or capable of automatic operation without manual intervention. 18.2.8, 19.2.8, 7.8				
K46	Emergency lighting of at least 1½ hour duration is provided automatically in accordance with 7.9. 18.2.9.1, 19.2.9.1.				
K105	2000 NEW (INDICATE N/A FOR EXISTING) Buildings equipped with or requiring the use of life support systems (electro-mechanical or inhalation anesthetics) have illumination of means of egress, emergency lighting equipment, exit, and directional signs supplied by the Life Safety Branch of the electrical system described in NFPA 99. 18.2.9.2., 18.2.10.2 (Indicate N/A if life support equipment is for emergency purposes only).				
EMERGENCY PLAN AND FIRE DRILLS					
K48	There is a written plan for the protection of all patients and for their evacuation in the event of an emergency. 18.7.1.1, 19.7.1.1				
K50	Fire drills include the transmission of a fire alarm signal and simulation of emergency fire conditions. Fire drills are held at unexpected times under varying conditions, at least quarterly on each shift. The staff is familiar with procedures and is aware that drills are part of established routine. Responsibility for planning and conducting drills is assigned only to competent persons who are qualified to exercise leadership. Where drills are conducted between 9:00 PM and 6:00 AM a coded announcement may be used instead of audible alarms. 18.7.1.2, 19.7.1.2				

ID PREFIX		MET	NOT MET	N/A	REMARKS
	<p>(Includes escalator emergency stop buttons and automatic skirt obstruction stop. For power dumbwaiters includes hoistway door locking to keep doors closed except for floor where car is being loaded or unloaded.)</p> <p>-----</p> <p>2000 NEW</p> <p>Escalators, dumbwaiters, and moving walks comply with the provisions of 9.4.</p> <p>All escalators and conveyors comply with ASME/ANSI A17.1, <i>Safety Code for Elevators and Escalators</i>. 18.5.3, 9.4.2.1</p>				
	FURNISHINGS AND DECORATIONS				
K73	<p>Combustible decorations shall be prohibited unless they are flame-retardant or in such limited quantity that hazard of fire development or spread is not present. 18.7.5.4, 19.7.5.4</p>				
K74	<p>Draperies, curtains, including cubicle curtains, and other loosely hanging fabrics and films serving as furnishings or decorations are flame resistant in accordance with NFPA 701 except for shower curtains. Sprinklers in areas where cubical curtains are installed shall be in accordance with NFPA 13 to avoid obstruction of the sprinkler. 10.3.1, 18.3.5.5, 19.3.5.5, 18.7.5.1, 19.7.5.1, NFPA 13</p> <p><input type="checkbox"/> Newly introduced upholstered furniture shall meet the char length and heat release criteria specified when tested in accordance with the methods cited in 10.3.2 (2) and 10.3.3, 18.7.5.2, 19.7.5.2.</p> <p><input type="checkbox"/> Newly introduced mattresses shall meet the char length and heat release criteria specified when tested in accordance with the method cited in 10.3.2 (3) and 10.3.4. 18.7.5.3, 19.7.5.3</p> <p><input type="checkbox"/> Newly introduced upholstered furniture and mattresses means purchased since March, 2003.</p>				
K75	<p>Soiled linen or trash collection receptacles shall not exceed 32 gal (121 L) in capacity. The average density of container capacity in a room or space shall not exceed .5 gal/ft² (20.4 L/m²). A</p>				